

ADDENDUM No. 1

To Bid Documents for
South Lawson Multi-Use Trail UPC 102982
RFP No: 23-004
City of Poquoson
November 17, 2022

The original Bid Documents for RFP No: 23-004 for UPC 102982 South Lawson Park Multi-Use Trail in the City of Poquoson, Virginia amended as noted in this Addendum No. 1, and the Addendum shall become part of the Bid Documents. Bidders must acknowledge receipt of this Addendum during the bidding process by signing the Bid Proposal when submitting proposals.

PRE-BID REQUEST FOR INFORMATION:

Questions regarding the bid items and plan sheets:

1. Plan Sheet No. 3&4:

There is no silt fence shown between the proposed path and the existing ditch, is this intentional?

The scope of work for the project involves very minor excavation and land disturbance, and therefore silt fence is only shown in areas where sediment could potentially sheet flow directly into the ponds adjacent to the work areas. Installation of the silt fence in itself causes earth disturbance and was not deemed necessary for areas outside of critical erosion (i.e. areas near the pond and BMP). The line item for silt fence in both the base bid and bid alternate represents approximately double the length of silt fence shown on the plans to account for replacement of silt fence (typically one replacement through the length of the project).

2. Bid Tab Pages 87&88 of IFB:

How will line item 10, siltation control excavation, be used during this project?

Siltation control excavation is provided for the contractor to remove built-up sediment from the silt fence (after each storm event, and when deposits reach one-half the height of the barrier, per VAESCH).

This Addendum shall be made a part of the solicitation documents.

Note: A signed acknowledgement of this addendum should be attached to your proposal.

Name of Bidder

Date

Signature

Title

END OF ADDENDUM NO. 1